

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Riverland Lot Owners Assoc

Had the following Violations Identified During a Drinking Water Inspection

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

A routine drinking water inspection conducted on 6/23/2022 by the state drinking water program identified the following violations that may pose a risk to public health.

Identified Violation	Date Correction is Required	Steps We Are Taking
F326 - Finished Water Storage: Tank No.2 (SDWIS ID: 005) Comprehensive Storage Tank Inspections Not Performed or Documented (T2): Supplier failed to perform or document a comprehensive tank inspection. This is a storage tank rule treatment technique violation of Regulation 11, Section 11.28(4)(c)(iii).	11/18/2022	During a sanitary survey conducted on June 23, 2022, a Tier 2 Violation was issued due to the storage tank not undergoing a Comprehensive Storage Tank Inspection. Subsequently, a Comprehensive Storage Tank Inspection was completed, revealing no issues with the tank, and the violation was resolved on November 17, 2022. However, it should be noted that the resolution of a Tier 2 violation necessitates a public notice, which unfortunately was not completed at the time of violation resolution.

- Inadequately treated or inadequately protected water may contain disease-causing organisms. These organisms can cause symptoms such as diarrhea, nausea, cramps, and associated headaches.
- Failure to perform the required start-up procedures prior to serving water to the public has the potential to distribute contaminated water. When our system shuts down operation, the lack of pressure in our pipes can allow the entry of bacteria and other disease-causing microorganisms into the drinking water. By performing start-up procedures such as flushing the pipes, disinfecting the water, and collecting a coliform bacteria sample before we open, we can be sure that we are providing you with safe water.
- Inadequately maintained storage tanks, identified through inspections, may allow contaminants or disease-causing organisms to enter the drinking water, which can cause diarrhea, nausea, cramps, and associated headaches.
- Uncontrolled cross connections can lead to a back pressure or siphonage event that may allow contaminants or disease-causing organisms to enter the drinking water, which can cause diarrhea, nausea, cramps, and associated headaches.

We also failed to notify you of the violation/situation in a timely manner.

What does this mean? What should I do?

- There is nothing you need to do at this time. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

We anticipate resolving the problem by **11/17/2022**. For more information, please contact **Brian Carney** at **westernwaterpros@gmail.com** or **970 901 0002**, or **PO 2776, Crested Butte, CO, 81224**.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: Riverland Lot Owners Assic - CO0126677
Date distributed: **3/1/2024**